

EMC TEST REPORT

For

ShenZhen XiangWei Measurement and Control Technology Co., Ltd

Locating leakage controller

Test Model: XW-PC-3/3A

Prepared for : ShenZhen XiangWei Measurement and Control Technology Co., Ltd

Address : 1609-1610 Jinhua Building, Taoxia Village, Gaofeng Community, Dalang Street, Longhua District, Shenzhen

Prepared by : Zhongshan LCS Compliance Testing Laboratory Ltd.

Address : 23F, Building A, Zhongshan Harbor of iDEAS, No. 25 Gangyi Road, Torch Development Zone, Zhongshan, Guangdong, China

Tel : (+86) 0760-85282956

Fax : (+86) 0760-85282906

Web : www.LCS-cert.com

Mail : webmaster@LCS-cert.com

Date of receipt of test sample : June 03, 2019

Number of tested samples : 1

Serial number : Prototype

Date of Test : June 03, 2019 ~ June 10, 2019

Date of Report : July 05, 2019



EMC TEST REPORT**EN 55032: 2015**



Information technology equipment-Radio disturbance characteristics – Limits of measurement

EN 55035: 2017


Electromagnetic compatibility of multimedia equipment – Immunity requirements

Report Reference No. : LCS190520040DE**Date of Issue..... : July 05, 2019****Testing Laboratory Name..... : Zhongshan LCS Compliance Testing Laboratory Ltd.****Address..... : 23F, Building A, Zhongshan Harbor of iDEAS, No. 25 Gangyi Road, Torch Development Zone, Zhongshan, Guangdong, China****Testing Location/ Procedure : Full application of Harmonised standards ☒**
Partial application of Harmonised standards ☐
Other standard testing method ☐**Applicant's Name : ShenZhen XiangWei Measurement and Control Technology Co., Ltd****Address..... : 1609-1610 Jinhua Building, Taoxia Village, Gaofeng Community, Dalang Street, Longhua District, Shenzhen****Test Specification****Standard..... : EN 55032: 2015**
EN 55035: 2017**Test Report Form No..... : LCSEMC-1.0****TRF Originator..... : Zhongshan LCS Compliance Testing Laboratory Ltd.****Master TRF..... : Dated 2011-03****Zhongshan LCS Compliance Testing Laboratory Ltd. All rights reserved.**

This publication may be reproduced in whole or in part for non-commercial purposes as long as the Zhongshan LCS Compliance Testing Laboratory Ltd. is acknowledged as copyright owner and source of the material. Zhongshan LCS Compliance Testing Laboratory Ltd. takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

Test Item Description..... : Locating leakage controller**Trade Mark..... :** **Test Model..... : XW-PC-3/3A****Ratings : DC 12V , 120mA****Result : Positive****Compiled by:**

Lylia Li/ File administrators

Supervised by:

Leo Lee/ Technique principal

Approved by:

Gavin Liang/ Manager

EMC -- TEST REPORT**Test Report No. : LCS190520040DE**July 05, 2019

Date of issue

Test Model..... : XW-PC-3/3A

EUT..... : Locating leakage controller

Applicant..... : ShenZhen XiangWei Measurement and Control Technology Co., LtdAddress..... : 1609-1610 Jinhua Building,Taoxia Village, Gaofeng
Community, Dalang Street, Longhua District, Shenzhen

Telephone..... : /

Fax..... : /

Manufacturer..... : ShenZhen XiangWei Measurement and Control Technology Co., LtdAddress..... : 1609-1610 Jinhua Building,Taoxia Village, Gaofeng
Community, Dalang Street, Longhua District, Shenzhen

Telephone..... : /

Fax..... : /

Factory..... : ShenZhen XiangWei Measurement and Control Technology Co., LtdAddress..... : 1609-1610 Jinhua Building,Taoxia Village, Gaofeng
Community, Dalang Street, Longhua District, Shenzhen

Telephone..... : /

Fax..... : /

Test Result**Positive**

The test report merely corresponds to the test sample.

It is not permitted to copy extracts of these test result without the written permission of the test laboratory.

Revision History

Revision	Issue Date	Revisions	Revised By
000	July 05, 2019	Initial Issue	Gavin Liang

TABLE OF CONTENTS

Test Report Description	Page
1. SUMMARY OF STANDARDS AND RESULTS	6
1.1. DESCRIPTION OF STANDARDS AND RESULTS	6
1.2. DESCRIPTION OF PERFORMANCE CRITERIA	7
2. GENERAL INFORMATION.....	8
2.1. DESCRIPTION OF DEVICE (EUT)	8
2.2. DESCRIPTION OF TEST FACILITY	8
2.3. STATEMENT OF THE MEASUREMENT UNCERTAINTY	8
2.4. MEASUREMENT UNCERTAINTY	9
3. MEASURING DEVICES AND TEST EQUIPMENT	10
4. RADIATED EMISSION MEASUREMENT	11
4.1. BLOCK DIAGRAM OF TEST SETUP	11
4.2. TEST STANDARD	11
4.3. EUT CONFIGURATION ON TEST	11
4.4. OPERATING CONDITION OF EUT	11
4.5. TEST PROCEDURE.....	12
4.6. TEST RESULTS.....	12
5. ELECTROSTATIC DISCHARGE IMMUNITY TEST.....	14
5.1. BLOCK DIAGRAM OF TEST SETUP	14
5.2. TEST STANDARD	14
5.3. SEVERITY LEVELS AND PERFORMANCE CRITERION	14
5.4. EUT CONFIGURATION ON TEST	14
5.5. OPERATING CONDITION OF EUT	14
5.6. TEST PROCEDURE.....	15
5.7. TEST RESULTS.....	15
6. RF FIELD STRENGTH SUSCEPTIBILITY TEST.....	17
6.1. BLOCK DIAGRAM OF TEST SETUP	17
6.2. TEST STANDARD	18
6.3. SEVERITY LEVELS AND PERFORMANCE CRITERION	18
6.4. EUT CONFIGURATION ON TEST	18
6.5. OPERATING CONDITION OF EUT	18
6.6. TEST PROCEDURE.....	18
6.7. TEST RESULTS.....	18
7. MAGNETIC FIELD SUSCEPTIBILITY TEST	20
7.1. BLOCK DIAGRAM OF TEST SETUP	20
7.2. TEST STANDARD	20
7.3. SEVERITY LEVELS AND PERFORMANCE CRITERION	20
7.4. EUT CONFIGURATION ON TEST	20
7.5. TEST PROCEDURE.....	20
7.6. TEST RESULTS.....	20
8. PHOTOGRAPHS OF TEST SETUP.....	22
9. PHOTOGRAPHS OF THE EUT	24

1. SUMMARY OF STANDARDS AND RESULTS

1.1. Description of Standards and Results

The EUT have been tested according to the applicable standards as referenced below.

Emission (EN 55032: 2015)			
Description of Test Item	Standard	Limits	Results
Conducted disturbance at mains terminals	EN 55032: 2015	Class B	N/A
Conducted disturbance at telecommunication port	EN 55032: 2015	Class B	N/A
Radiated disturbance	EN 55032: 2015	Class B	PASS
Harmonic current emissions	EN 61000-3-2: 2014	Class A	N/A
Voltage fluctuations & flicker	EN 61000-3-3: 2013	-----	N/A
Immunity (EN 55035: 2017)			
Description of Test Item	Basic Standard	Performance Criteria	Results
Electrostatic discharge (ESD)	EN 61000-4-2: 2009	B	PASS
Radio-frequency, Continuous radiated disturbance	EN 61000-4-3: 2006+A2: 2010	A	PASS
Electrical fast transient (EFT)	EN 61000-4-4: 2012	B	N/A
Surge (Input a.c. power ports)	EN 61000-4-5: 2014+A1: 2017	B	N/A
Surge (Telecommunication ports)		B	N/A
Radio-frequency, Continuous conducted disturbance	EN 61000-4-6: 2014	A	N/A
Power frequency magnetic field	EN 61000-4-8: 2010	A	PASS
Voltage dips, >95% reduction	EN 61000-4-11: 2004+A1: 2017	B	N/A
Voltage dips, 30% reduction		C	N/A
Voltage interruptions		C	N/A
***Note: N/A is an abbreviation for Not Applicable.			

Test mode:

Mode 1	Working	Record
--------	---------	--------

1.2. Description of Performance Criteria

General Performance Criteria

Examples of functions defined by the manufacturer to be evaluated during testing include, but are not limited to, the following:

- essential operational modes and states;
- tests of all peripheral access (hard disks, floppy disks, printers, keyboard, mouse, etc.);
- quality of software execution;
- quality of data display and transmission;
- quality of speech transmission.

1.2.1. Performance criterion A

The equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed below a performance level specified by the manufacture when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.2. Performance criterion B

After the test, the equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed, after the application of the phenomena below a performance level specified by the manufacture, when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance.

During the test, degradation of performance is allowed. However, no change of operation state or stored data is allowed to persist after the test.

If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.3. Performance criterion C

Loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls by the user in accordance with the manufacture's instructions.

Functions, and/or information stored in non-volatile memory, or protected by a battery backup, shall not be lost.

2. GENERAL INFORMATION

2.1. Description of Device (EUT)

EUT : Locating leakage controller

Trade Mark : 

Test Model : XW-PC-3/3A

Power Supply : DC 12V , 120mA

EUT Clock Frequency : \leq 108MHz

2.2. Description of Test Facility

FCC Registration Number is 254912.

Industry Canada Registration Number is 9642A-1.

ESMD Registration Number is ARCB0108.

UL Registration Number is 100571-492.

TUV SUD Registration Number is SCN1081.

TUV RH Registration Number is UA 50296516-001

NVLAP Registration Code is 600167-0.

2.3. Statement of The Measurement Uncertainty

The data and results referenced in this document are true and accurate. The reader is cautioned that there may be errors within the calibration limits of the equipment and facilities. The measurement uncertainty was calculated for all measurements listed in this test report acc. To CISPR 16 – 4 “Specification for radio disturbance and immunity measuring apparatus and methods – Part 4: Uncertainty in EMC Measurements” and is documented in the LCS quality system acc. To DIN EN ISO/IEC 17025. Furthermore, component and process variability of devices similar to that tested may result in additional deviation. The manufacturer has the sole responsibility of continued compliance of the device.

2.4. Measurement Uncertainty

Test	Parameters	Expanded Uncertainty (U_{lab})	Expanded Uncertainty (U_{cisp})
Conducted Emission	Level accuracy (9kHz to 150kHz) (150kHz to 30MHz)	± 2.63 dB ± 2.35 dB	± 3.8 dB ± 3.4 dB
Power Disturbance	Level accuracy (30MHz to 300MHz)	± 2.90 dB	± 4.5 dB
Electromagnetic Radiated Emission (3-loop)	Level accuracy (9kHz to 30MHz)	± 3.60 dB	± 3.3 dB
Radiated Emission	Level accuracy (9kHz to 30MHz)	± 3.68 dB	N/A
Radiated Emission	Level accuracy (30MHz to 1000MHz)	± 3.48 dB	± 5.3 dB
Radiated Emission	Level accuracy (above 1000MHz)	± 3.90 dB	± 5.2 dB
Mains Harmonic	Voltage	$\pm 0.510\%$	N/A
Voltage Fluctuations & Flicker	Voltage	$\pm 0.510\%$	N/A
EMF	/	$\pm 21.59\%$	N/A
1) Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the apparatus. 2) The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor of $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.			

3. MEASURING DEVICES AND TEST EQUIPMENT

Test Item: Radiated Disturbance (Electric Field)

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Software	AUDIX	E3	/	2018-06-16
2	3m Semi Anechoic Chamber	SIDT FRANKONIA	SAC-3M	03CH03-HY	2018-06-16
3	Positioning Controller	MF	MF-7082	/	2018-06-16
4	By-log Antenna	SCHWARZBECK	VULB9163	9163-470	2018-07-26
5	Horn Antenna	SCHWARZBECK	BBHA 9120D	9120D-1925	2018-07-02
6	EMI Test Receiver	R&S	ESR 7	101181	2018-06-16
7	RS SPECTRUM ANALYZER	R&S	FSP40	100503	2018-11-15
8	AMPLIFIER	QuieTek	QTK	CHM/0809065	2018-11-15
9	RF Cable-R03m	Jye Bao	RG142	CB021	2018-06-16
10	RF Cable-HIGH	SUHNER	SUCOFLEX 106	03CH03-HY	2018-06-16

Test Item: Electrostatic Discharge

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	ESD Simulator	SCHLODER	SESD 230	604035	2018-07-02

Test Item: RF Field Strength Susceptibility

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	RS Test Software	Tonscend	/	/	2018-06-16
2	ESG Vector Signal Generator	Agilent	E4438C	MY42081396	2018-11-15
3	3m Semi Anechoic Chamber	SIDT FRANKONIA	SAC-3M	03CH03-HY	2018-06-16
4	RF POWER AMPLIFIER	OPHIR	5225R	1052	NCR
5	RF POWER AMPLIFIER	OPHIR	5273F	1019	NCR
6	Stacked Broadband Log Periodic Antenna	SCHWARZBECK	STLP 9128	9128ES-145	NCR
7	Stacked Mikrowellen Log.-Per Antenna	SCHWARZBECK	STLP 9149	9149-484	NCR
8	Electric field probe	Narda S.TS./PMM	EP601	611WX80208	2018-03-26


Note: NCR means no calibration requirement

Test Item: Power Frequency Magnetic Field Susceptibility

Item	Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power frequency mag-field generator System	EVERFINE	EMS61000-8K	906003	2018-06-16

4. RADIATED EMISSION MEASUREMENT

4.1. Block Diagram of Test Setup



4.2. Test Standard

EN 55032: 2015 Class B

All emanations from a class B device or system, including any network of conductors and apparatus connected thereto, shall not exceed the level of field strengths specified below:

Limits for Radiated Emission Below 1GHz		
Frequency (MHz)	Distance (Meters)	Field Strengths Limit (dB μ V/m)
30 ~ 230	3	40
230 ~ 1000	3	47

***Note:

(1) The smaller limit shall apply at the combination point between two frequency bands.

(2) Distance refers to the distance in meters between the measuring instrument antenna and the closed point of any part of the EUT.

4.3. EUT Configuration on Test

The EN 55032 regulations test method must be used to find the maximum emission during radiated emission measurement.

4.4. Operating Condition of EUT

- 1) Turn on the power.
- 2) Let the EUT work in the test mode (1) and measure it.

4.5. Test Procedure

The EUT is placed on a turntable, which is 0.8 meter high above the ground. The turntable can rotate 360 degrees to determine the position of the maximum emission level. The EUT is set 3 meters away from the receiving antenna, which is mounted on a antenna tower. The antenna can be moved up and down from 1 to 4 meters to find out the maximum emission level. By-log antenna is used as a receiving antenna. Both horizontal and vertical polarization of the antenna is set on test.

The bandwidth of the EMI test receiver is set at RBW/VBW=120kHz/1000kHz.


The frequency range from 30MHz to 1000MHz is checked.

4.6. Test Results

PASS.

The test result please refer to the next page.


Test Model	XW-PC-3/3A	Test Mode	Mode 1
Environmental Conditions	23.8°C, 53.7% RH	Detector Function	Quasi-peak
Pol.	Vertical	Distance	3m
Test Engineer	Jay Li		



	Freq	Reading	CabLos	Antfac	Measured	Limit	Over	Remark
	MHz	dBuV	dB	dB/m	dBuV/m	dBuV/m	dB	
1	47.33	13.91	0.35	13.41	27.67	40.00	-12.33	QP
2	100.93	10.42	0.60	13.08	24.10	40.00	-15.90	QP
3	139.36	19.22	0.75	8.24	28.21	40.00	-11.79	QP
4	282.99	13.16	1.06	12.73	26.95	47.00	-20.05	QP
5	431.03	20.94	1.28	15.52	37.74	47.00	-9.26	QP
6	449.56	17.43	1.27	15.57	34.27	47.00	-12.73	QP

Note: 1. All readings are Quasi-peak values.
 2. Measured= Reading + Antenna Factor + Cable Loss
 3. The emission that are 20db below the official limit are not reported

Test Model	XW-PC-3/3A	Test Mode	Mode 1
Environmental Conditions	23.8°C, 53.7% RH	Detector Function	Quasi-peak
Pol.	Horizontal	Distance	3m
Test Engineer	Jay Li		




	Freq	Reading	CabLos	Antfac	Measured	Limit	Over	Remark
	MHz	dBuV	dB	dB/m	dBuV/m	dBuV/m	dB	
1	32.63	-1.25	0.37	12.31	11.43	40.00	-28.57	QP
2	95.43	-1.04	0.58	12.87	12.41	40.00	-27.59	QP
3	139.85	5.25	0.75	8.20	14.20	40.00	-25.80	QP
4	284.98	16.13	1.00	12.77	29.90	47.00	-17.10	QP
5	432.55	10.16	1.18	15.53	26.87	47.00	-20.13	QP
6	490.74	4.77	1.32	16.34	22.43	47.00	-24.57	QP

Note: 1. All readings are Quasi-peak values.
 2. Measured= Reading + Antenna Factor + Cable Loss
 3. The emission that are 20db below the official limit are not reported

Remark: Pre-San all mode, Thus record worse case mode result in this report

5. ELECTROSTATIC DISCHARGE IMMUNITY TEST

5.1. Block Diagram of Test Setup



5.2. Test Standard

EN 55035: 2017 (EN 61000-4-2: 2009, Severity Level: 3 / Air Discharge: $\pm 8\text{KV}$, Level: 2 / Contact Discharge: $\pm 4\text{KV}$)

5.3. Severity Levels and Performance Criterion

5.3.1. Severity level

Level	Test Voltage Contact Discharge (KV)	Test Voltage Air Discharge (KV)
1	± 2	± 2
2	± 4	± 4
3	± 6	± 8
4	± 8	± 15
X	Special	Special

5.3.2. Performance Criterion

Performance Criterion: B

5.4. EUT Configuration on Test

The configuration of EUT is listed in Section 4.3.

5.5. Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 3.2. Except the test set up replaced by Section 5.1.

5.6. Test Procedure

5.6.1. Air Discharge

This test is done on a non-conductive surface. The round discharge tip of the discharge electrode shall be approached as fast as possible to touch the EUT. After each discharge, the discharge electrode shall be removed from the EUT. The generator is then re-triggered for a new single discharge and repeated 10 times for each pre-selected test point. This procedure shall be repeated until all the air discharge completed

5.6.2. Contact Discharge

All the procedure shall be same as Section 5.6.1. Except that the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.

5.6.3. Indirect Discharge For Horizontal Coupling Plane

At least 10 single discharges (in the most sensitive polarity) shall be applied at the front edge of each HCP opposite the center point of each unit (if applicable) of the EUT and 0.1m from the front of the EUT. The long axis of the discharge electrode shall be in the plane of the HCP and perpendicular to its front edge during the discharge.

5.6.4. Indirect Discharge For Vertical Coupling Plane

At least 10 single discharge (in the most sensitive polarity) shall be applied to the center of one vertical edge of the coupling plane. The coupling plane, of dimensions 0.5m X 0.5m, is placed parallel to, and positioned at a distance of 0.1m from the EUT. Discharges shall be applied to the coupling plane, with this plane in sufficient different positions that the four faces of the EUT are completely illuminated.

5.7. Test Results

PASS.

The test result please refer to the next page.


Electrostatic Discharge Test Results

Standard	<input type="checkbox"/> IEC 61000-4-2 <input checked="" type="checkbox"/> EN 61000-4-2		
Applicant	ShenZhen XiangWei Measurement and Control Technology Co., Ltd		
EUT	Locating leakage controller	Temperature	22.3℃
M/N	XW-PC-3/3A	Humidity	53.5%
Criterion	B	Pressure	1021mbar
Test Mode	Mode 1	Test Engineer	Jay Li

Air Discharge						
Test Points	Test Levels			Results		
	± 2kV	± 4kV	± 8kV	Passed	Fail	Performance Criterion
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Top	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Bottom	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Contact Discharge						
Test Points	Test Levels		Results			
	± 2 kV	±4 kV	Passed	Fail	Performance Criterion	
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Top	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Bottom	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Discharge To Horizontal Coupling Plane						
Side of EUT	Test Levels		Results			
	± 2 kV	± 4 kV	Passed	Fail	Performance Criterion	
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Discharge To Vertical Coupling Plane						
Side of EUT	Test Levels		Results			
	± 2 kV	± 4 kV	Passed	Fail	Performance Criterion	
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A	<input checked="" type="checkbox"/> B

6. RF FIELD STRENGTH SUSCEPTIBILITY TEST

6.1. Block Diagram of Test Setup



6.2. Test Standard

EN 55035: 2017 (EN 61000-4-3: 2006+A2: 2010 Severity Level: 2, 3V/m)

6.3. Severity Levels and Performance Criterion

6.3.1. Severity level

Level	Field Strength (V/m)
1	1
2	3
3	10
X	1

6.3.2. Performance Criterion

Performance Criterion: A

6.4. EUT Configuration on Test

The configuration of EUT is listed in Section 4.3.

6.5. Operating Condition of EUT

Same as radiated emission measurement, which is listed in Section 5.1, except the test setup replaced as Section 6.1.

6.6. Test Procedure

The EUT are placed on a table, which is 0.8 meter high above the ground. The EUT is set 3 meters away from the transmitting antenna, which is mounted on an antenna tower. Both horizontal and vertical polarization of the antenna is set on test. Each of the four sides of the EUT must be faced this transmitting antenna and measured individually.

In order to judge the EUT performance, a CCD Recording is used to monitor its screen.

All the scanning conditions are as following:

Condition of Test	Remark
Fielded Strength	3 V/m (Severity Level 2)
Radiated Signal	Unmodulated
Test Frequency Range (swept test)	80-1000MHz
Test Frequency (spot test)	1800MHz, 2600MHz, 3500MHz, 5000MHz
Dwell time of radiated	0.0015 decade/s
Waiting Time	3 Sec.

6.7. Test Results

PASS.

The test result please refer to the next page.

RF Field Strength Susceptibility Test Results

Standard	<input type="checkbox"/> IEC 61000-4-3 <input checked="" type="checkbox"/> EN 61000-4-3		
Applicant	ShenZhen XiangWei Measurement and Control Technology Co., Ltd		
EUT	Locating leakage controller	Temperature	23.7°C
M/N	XW-PC-3/3A	Humidity	52.4%
Field Strength	3 V/m	Criterion	A
Test Mode	Mode 1	Test Engineer	Jay Li
Test Frequency	80MHz to 1000MHz (swept test) 1800MHz, 2600MHz, 3500MHz, 5000MHz (spot test)		
Modulation	<input type="checkbox"/> None <input type="checkbox"/> Pulse <input checked="" type="checkbox"/> AM 1KHz 80%		
Steps	1%		

	Horizontal	Vertical
Front	PASS	PASS
Right	PASS	PASS
Rear	PASS	PASS
Left	PASS	PASS


Test Equipment:

1. Signal Generator: 2031 (MARCONI)
2. Power Amplifier: 500A100 & 100W/1000M1 (A&R)
3. Power Antenna: 3108 (EMCO) & AT1080 (A&R)
4. Field Monitor: FM2000 (A&R)

Note:

7. MAGNETIC FIELD SUSCEPTIBILITY TEST

7.1. Block Diagram of Test Setup



7.2. Test Standard

EN 55035: 2017 (EN 61000-4-8: 2010, Severity Level: Level 1, 1A/m)

7.3. Severity Levels and Performance Criterion

7.3.1. Severity level

Level	Field Strength (A/m)
1	1
2	3
3	10
4	30
5	100
X	Special

7.3.2. Performance Criterion

Performance Criterion: A

7.4. EUT Configuration on Test

The configuration of EUT is listed in Section 3.4.

7.5. Test Procedure

The EUT is placed in the middle of a induction coil (1*1m), under which is a 1*1*0.1m (high) table, this small table is also placed on a larger table, 0.8 m above the ground. Both horizontal and vertical polarization of the induction coil is set on test, so that each side of the EUT is affected by the magnetic field. Also can reach the same aim by change the position of the EUT.

7.6. Test Results

PASS.

The test result please refer to the next page.


Magnetic Field Immunity Test Result

Standard	<input type="checkbox"/> IEC 61000-4-8 <input checked="" type="checkbox"/> EN 61000-4-8		
Applicant	ShenZhen XiangWei Measurement and Control Technology Co., Ltd		
EUT	Locating leakage controller	Temperature	24.2°C
M/N	XW-PC-3/3A	Humidity	52.6%
Test Mode	Mode 1	Criterion	A
Test Engineer	Jay Li		

Test Level (A/M)	Testing Duration	Coil Orientation	Criterion	Result
1	5 mins	X	A	PASS
1	5 mins	Y	A	PASS
1	5 mins	Z	A	PASS

Note:


8. PHOTOGRAPHS OF TEST SETUP



Test Setup Photo of Radiated Measurement (30MHz~1GHz)



Test Setup Photo of Electrostatic Discharge Test



Test Setup Photo of RF Electromagnetic Field Measurement



Test Setup Photo of Magnetic Field Immunity Test

9. PHOTOGRAPHS OF THE EUT




Fig. 1




Fig. 2




Fig. 3



Fig. 4




Fig. 5




Fig. 6

----- THE END OF TEST REPORT -----